REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT					
FACILITY NAME: Gorgas Steam Plant – Ash Pond Dam					
OWNER/OPERATOR OF FACILITY: Alabama Power Company					
INSPECTION DATE: October 15, 2019					
INSPECTING ENGINEER: Jacob A. Jordan, P.E. (Alabama P.E. License #25093)					
Southern Company Services, Technical Services – Senior Engineer, Fossil Dam Safety					
ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE			NO		
SINCE THE PREVIOUS ANNUAL INSPECTION?					
(IF YES, DESCRIBE):					
LOCATION AND TYPE OF EXISTING INSTRUMENTATION			See Attached Table 1		
MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE			Deformation Monuments Only		
PREVIOUS ANNUAL INSPECTION	ALINA AND DECE	NT DEDTH AND	ELEVATION:	OF THE MADOLINIDED	
APPROXIMATE MINIMUM, MAXII WATER SINCE PREVIOUS ANNUA		NI DEPIH AND	ELEVATION	OF THE IMPOUNDED	
MIN. DEPTH: less than 1 foot	MAX. DEPTH: 62 ft		PRESENT DEPTH: up to 62 feet		
MIN. ELEVATION: EL 320 ft	MAX. ELEVATION: EL 382 ft		PRESENT. ELEVATION: EL 382 ft		
			The first and the second of the Contract of th		
ANNUAL INSPECTION.	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS				
MIN. DEPTH: less than 1 ft	MAX. DEPTH: 12	Ω ft	PRESENT DEPTH: up to 120 feet		
MIN. ELEVATION: EL 270 ft (est.)	MAX. ELEVATION: EL 387 ft		PRESENT ELEVATION: up to EL		
Willy. ELEVATION. EL 270 IC (est.)	WAX. CLEVATION. LE 367 IL		387 ft		
APPROXIMATE STORAGE CAPACITY OF					
IMPOUNDING STRUCTURE AT TIM	29,000,000 cubic yards				
INSPECTION.					
APPROXIMATE VOLUME OF IMPOUNDED WATER		WATER: 4,000	) 000 vd3*	CCR: 25,000,000 yd <sup>3</sup> *	
AND CCR AT TIME OF INSPECTION			,,000 yu	<b>CCN</b> : 25,000,000 yu	
ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL					
WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING			NO		
CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL					
TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?					
(IF YES, DESCRIBE):					
(IF TES, DESCRIBE).					
ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE					
STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL			NO		
INSPECTION?					
(IF YES, DESCRIBE):					

<sup>\*</sup>Volume figures are estimated derived from available information.

Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b) and ADEM Admin. Code r. 335-13-15-.05(4)(b).

Jacob A. Jordan, P.E.

1/17/20 Date

TABLE 1: INSTRUMENTATION TYPE AND LOCATION - GORGAS ASH POND				
INSTRUMENT NUMBER	INSTRUMENT TYPE	LOCATION		
SM-101	Deformation Survey Monument (Vertical and Horizontal)	Crest (Top) of Dam, Near Left (West ) Abutment		
SM-102	Deformation Survey Monument (Vertical and Horizontal)	Crest of Dam, Left Portion of Dam		
SM-103	Deformation Survey Monument (Vertical and Horizontal)	Crest of Dam, Center-Left Portion of Dam		
SM-104	Deformation Survey Monument (Vertical and Horizontal)	Crest of Dam, Center-Right (East) Portion of Dam		
SM-105	Deformation Survey Monument (Vertical and Horizontal)	Crest of Dam, Right Portion of Dam		
SM-106	Deformation Survey Monument (Vertical and Horizontal)	Crest of Dam, Near Right Abutment		
WEIR	Seepage Weir	Toe (Bottom) of Ash Pond, Center-Right portion of dam		