


| REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT | | |
|---|--|--|
| FACILITY NAME: Gorgas Steam Plant – Gypsum Pond | | |
| OWNER/OPERATOR OF FACILITY: Alabama Power Company | | |
| INSPECTION DATE: March 31, 2021 | | |
| INSPECTING ENGINEER: Jacob A. Jordan, P.E. (Alabama P.E. License #25093) Southern Company Services - Principal Engineer, Fossil Dam Safety | | |
| ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? | NO | |
| (IF YES, DESCRIBE): | | |
| | | |
| LOCATION AND TYPE OF EXISTING INSTRUMENTATION | N/A (No instrumentation) | |
| MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION | N/A (No instrumentation) | |
| APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION | | |
| MIN. DEPTH: less than 1 foot | MAX. DEPTH: 7 ft | PRESENT DEPTH: < 1 foot* |
| MIN. ELEVATION: N/A | MAX. ELEVATION: EL 430 ft | PRESENT. ELEVATION: N/A |
| APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. | | |
| MIN. DEPTH: less than 1 ft | MAX. DEPTH: 52 ft | PRESENT DEPTH: up to 35 feet* |
| MIN. ELEVATION: EL 405 ft (est.) | MAX. ELEVATION: EL 457 ft | PRESENT ELEVATION: up to EL 445 ft (with stack)* |
| APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION. | 1,000,000 cubic yards (with stacking)* | |
| APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION | WATER: 0 yd ^{3**} | CCR: 186,000 yd ^{3**} |
| ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? | NO | |
| (IF YES, DESCRIBE): | | |
| | | |
| ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? | NO | |
| (IF YES, DESCRIBE): | | |
| | | |

*Gypsum is being removed from the pond for beneficial reuse purposes and the pond has been substantially dewatered. Any water present in the pond is temporary stormwater retention after rainfall

**Volume figures are estimated derived from available information.

Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b) and ADEM Admin. Code r. 335-13-15-.05(4)(b).



Jacob A. Jordan, P.E.



1/14/2022
Date